

# Anatek Labs, Inc.

1282 Alturas Drive • Moscow, ID 83843 • (208) 883-2839 • Fax (208) 882-9246 • email moscow@anateklabs.com  
504 E Sprague Ste. D • Spokane WA 99202 • (509) 838-3999 • Fax (509) 838-4433 • email spokane@anateklabs.com

**Client:** TOWN OF COUPEVILLE  
**Address:** P.O. BOX 725  
COUPEVILLE, WA 98239  
**Attn:** JOSEPH GROGAN

**Batch #:** 170628047  
**Project Name:** EPA 537


## Analytical Results Report

Sample Number	170628047-001	Sampling Date	6/27/2017	Date/Time Received	6/28/2017 1:00 PM			
Client Sample ID	1-08	Sampling Time	7:30 AM	Extraction Date	6/29/2017			
Matrix	Drinking Water	Sample Location						
Parameter	Result	Units	MDL	PQL	Analysis Date	Analyst	Method	Qualifier
Perfluorobutanesulfonic acid - PF	ND	ug/L	0.025	0.09	6/30/2017	TGT	EPA 537	
Perfluoroheptanoic acid - PFHpA	0.00919	ug/L	0.005	0.01	6/30/2017	TGT	EPA 537	J
Perfluorohexanesulfonic acid - P	0.0528	ug/L	0.005	0.03	6/30/2017	TGT	EPA 537	
Perfluorononanoic acid - PFNA	ND	ug/L	0.005	0.02	6/30/2017	TGT	EPA 537	
Perfluorooctanesulfonic acid - PFOS	ND	ug/L	0.01	0.04	6/30/2017	TGT	EPA 537	
Perfluorooctanoic acid - PFOA	0.0543	ug/L	0.005	0.02	6/30/2017	TGT	EPA 537	

Sample Number	170628047-002	Sampling Date	6/27/2017	Date/Time Received	6/28/2017 1:00 PM			
Client Sample ID	DIST	Sampling Time	7:30 AM	Extraction Date	6/29/2017			
Matrix	Drinking Water	Sample Location						
Parameter	Result	Units	MDL	PQL	Analysis Date	Analyst	Method	Qualifier
Perfluorobutanesulfonic acid - PF	ND	ug/L	0.025	0.09	6/30/2017	TGT	EPA 537	
Perfluoroheptanoic acid - PFHpA	ND	ug/L	0.005	0.01	6/30/2017	TGT	EPA 537	
Perfluorohexanesulfonic acid - P	0.0295	ug/L	0.005	0.03	6/30/2017	TGT	EPA 537	J
Perfluorononanoic acid - PFNA	ND	ug/L	0.005	0.02	6/30/2017	TGT	EPA 537	
Perfluorooctanesulfonic acid - PFOS	ND	ug/L	0.01	0.04	6/30/2017	TGT	EPA 537	
Perfluorooctanoic acid - PFOA	0.0305	ug/L	0.005	0.02	6/30/2017	TGT	EPA 537	

Authorized Signature

  
Kathleen A. Sattler, Lab Manager

J The reported value is between the laboratory method detection limit and the laboratory practical quantitation limit.  
MCL EPA's Maximum Contaminant Level  
ND Not Detected  
PQL Practical Quantitation Limit

This report shall not be reproduced except in full, without the written approval of the laboratory.  
The results reported relate only to the samples indicated.  
Soil/solid results are reported on a dry-weight basis unless otherwise noted.

Certifications held by Anatek Labs ID: EPA:ID00013; AZ:0701; FL(NELAP):E87893; ID:ID00013; MT:Cert0028; NM: ID00013; NV:ID00013; OR:ID200001-002; WA:C595  
Certifications held by Anatek Labs WA: EPA:WA00169; ID:WA00169; WA:C585; MT:Cert0095; FL(NELAP): E871099

Friday, July 07, 2017

Page 1 of 1