

Anatek Labs, Inc.

1282 Alturas Drive • Moscow, ID 83843 • (208) 883-2839 • Fax (208) 882-9246 • email moscow@anateklabs.com
504 E Sprague Ste. D • Spokane WA 99202 • (509) 838-3999 • Fax (509) 838-4433 • email spokane@anateklabs.com

Client: TOWN OF COUPEVILLE
Address: P.O. BOX 725
COUPEVILLE, WA 98239
Attn: JOSEPH GROGAN

Batch #: 170329059
Project Name: 537
PWS #: 155509

Analytical Results Report

Sample Number	170329059-001	Sampling Date	3/28/2017	Date/Time Received	3/29/2017 1:55 PM
Client Sample ID	DIST	Sampling Time	2:00 PM	Extraction Date	4/3/2017
Matrix	Drinking Water	Facility ID		Sample Point ID	I
Sample Location		Comments			

Parameter	Result	Units	PQL	Analysis Date	Analyst	Method	Qualifier
Perfluorobutanesulfonic acid - PFBS	ND	ug/L	0.09	4/4/2017	TGT	EPA 537	
Perfluoroheptanoic acid - PFHpA	< 0.005	ug/L	0.01	4/4/2017	TGT	EPA 537	
Perfluorohexanesulfonic acid - PFHxS	0.0292	ug/L	0.03	4/4/2017	TGT	EPA 537	J
Perfluorononanoic acid - PFNA	ND	ug/L	0.02	4/4/2017	TGT	EPA 537	
Perfluorooctanesulfonic acid - PFOS	ND	ug/L	0.04	4/4/2017	TGT	EPA 537	
Perfluorooctanoic acid - PFOA	0.0362	ug/L	0.02	4/4/2017	TGT	EPA 537	

Surrogate Data

Sample Number	170329059-001			
Surrogate Standard	Method	Percent Recovery	Control Limits	
13C-PFDA	EPA 537	86.0	70-130	
13C-PFHxA	EPA 537	83.6	70-130	

Anatek Labs, Inc.

1282 Alturas Drive • Moscow, ID 83843 • (208) 883-2839 • Fax (208) 882-9246 • email moscow@anateklabs.com
504 E Sprague Ste. D • Spokane WA 99202 • (509) 838-3999 • Fax (509) 838-4433 • email spokane@anateklabs.com

Client: TOWN OF COUPEVILLE
Address: P.O. BOX 725
COUPEVILLE, WA 98239
Attn: JOSEPH GROGAN

Batch #: 170329059
Project Name: 537
PWS #: 155509

Analytical Results Report

Sample Number	170329059-002	Sampling Date	3/28/2017	Date/Time Received	3/29/2017 1:55 PM
Client Sample ID	1-08	Sampling Time	1:40 PM	Extraction Date	4/3/2017
Matrix	Drinking Water	Facility ID		Sample Point ID	I
Sample Location		Comments			

Parameter	Result	Units	PQL	Analysis Date	Analyst	Method	Qualifier
Perfluorobutanesulfonic acid - PFBS	ND	ug/L	0.09	4/4/2017	TGT	EPA 537	
Perfluoroheptanoic acid - PFHpA	0.00900	ug/L	0.01	4/4/2017	TGT	EPA 537	J
Perfluorohexanesulfonic acid - PFHxS	0.0570	ug/L	0.03	4/4/2017	TGT	EPA 537	
Perfluorononanoic acid - PFNA	ND	ug/L	0.02	4/4/2017	TGT	EPA 537	
Perfluorooctanesulfonic acid - PFOS	ND	ug/L	0.04	4/4/2017	TGT	EPA 537	
Perfluorooctanoic acid - PFOA	0.0642	ug/L	0.02	4/4/2017	TGT	EPA 537	

Surrogate Data

Sample Number	170329059-002		
Surrogate Standard	Method	Percent Recovery	Control Limits
13C-PFDA	EPA 537	93.0	70-130
13C-PFHxA	EPA 537	90.6	70-130

Anatek Labs, Inc.

1282 Alturas Drive • Moscow, ID 83843 • (208) 883-2839 • Fax (208) 882-9246 • email moscow@anateklabs.com
504 E Sprague Ste. D • Spokane WA 99202 • (509) 838-3999 • Fax (509) 838-4433 • email spokane@anateklabs.com

Client: TOWN OF COUPEVILLE
Address: P.O. BOX 725
COUPEVILLE, WA 98239
Attn: JOSEPH GROGAN

Batch #: 170329059
Project Name: 537
PWS #: 155509

Analytical Results Report

Sample Number	170329059-003	Sampling Date	3/28/2017	Date/Time Received	3/29/2017 1:55 PM
Client Sample ID	2-87	Sampling Time	1:40 PM	Extraction Date	4/3/2017
Matrix	Drinking Water	Facility ID		Sample Point ID	I
Sample Location		Comments			

Parameter	Result	Units	PQL	Analysis Date	Analyst	Method	Qualifier
Perfluorobutanesulfonic acid - PFBS	ND	ug/L	0.09	4/4/2017	TGT	EPA 537	
Perfluoroheptanoic acid - PFHpA	ND	ug/L	0.01	4/4/2017	TGT	EPA 537	
Perfluorohexanesulfonic acid - PFHxS	ND	ug/L	0.03	4/4/2017	TGT	EPA 537	
Perfluorononanoic acid - PFNA	ND	ug/L	0.02	4/4/2017	TGT	EPA 537	
Perfluorooctanesulfonic acid - PFOS	ND	ug/L	0.04	4/4/2017	TGT	EPA 537	
Perfluorooctanoic acid - PFOA	ND	ug/L	0.02	4/4/2017	TGT	EPA 537	

Surrogate Data

Sample Number	170329059-003			
Surrogate Standard	Method	Percent Recovery	Control Limits	
13C-PFDA	EPA 537	80.8	70-130	
13C-PFHxA	EPA 537	81.6	70-130	

Authorized Signature


Kathy Sattler, Lab Manager

J The reported value is between the laboratory method detection limit and the laboratory practical quantitation limit.
MCL EPA's Maximum Contaminant Level
ND Not Detected
PQL Practical Quantitation Limit

This report shall not be reproduced except in full, without the written approval of the laboratory.
The results reported relate only to the samples indicated.
Soil/solid results are reported on a dry-weight basis unless otherwise noted.

Certifications held by Anatek Labs ID: EPA.ID00013; AZ.0701; FL(NELAP).E87893; ID.ID00013; MT.CERT0028; NM.ID00013; NV.ID00013; OR.ID200001-002; WA.C595
Certifications held by Anatek Labs WA: EPA.WA00169; ID.WA00169; WA.C585; MT.Cert0095; FL(NELAP).E871099