

APR 24 2018

Anatek Labs, Inc.

TOWN OF COUPEVILLE

1282 Alturas Drive • Moscow, ID 83843 • (208) 883-2839 • Fax (208) 882-9246 • email moscow@anateklabs.com
 504 E Sprague Ste. D • Spokane WA 99202 • (509) 838-3999 • Fax (509) 838-4433 • email spokane@anateklabs.com

Client: TOWN OF COUPEVILLE
Address: P.O. BOX 725
 COUPEVILLE, WA 98239
Attn: JOSEPH GROGAN


Batch #: 180326034
Project Name: EPA 537

Analytical Results Report

Sample Number	180326034-002	Sampling Date	3/23/2018	Date/Time Received	3/26/2018 9:52 AM
Client Sample ID	DIST	Sampling Time	9:40 AM	Extraction Date	4/4/2018
Matrix	Drinking Water	Sample Location			
Comments					

Parameter	Result	Units	MDL	PQL	Analysis Date	Analyst	Method	Qualifier
Perfluorobutanesulfonic acid - PF BS ^{BS}	ND	ug/L	0.025	0.09	4/10/2018	TGT	EPA 537	
Perfluoroheptanoic acid - PFHpA	0.00607	ug/L	0.005	0.01	4/10/2018	TGT	EPA 537	J
Perfluorohexanesulfonic acid - PF HXS ^{HXS}	0.0356	ug/L	0.005	0.03	4/10/2018	TGT	EPA 537	
Perfluorononanoic acid - PFNA	ND	ug/L	0.005	0.02	4/10/2018	TGT	EPA 537	
Perfluorooctanesulfonic acid - PF OS ^{OS}	ND	ug/L	0.01	0.04	4/10/2018	TGT	EPA 537	
Perfluorooctanoic acid - PFOA	0.0374	ug/L	0.005	0.02	4/10/2018	TGT	EPA 537	

Authorized Signature



 Kathleen A. Sattler, Lab Manager

- J The reported value is between the laboratory method detection limit and the laboratory practical quantitation limit.
- MCL EPA's Maximum Contaminant Level
- ND Not Detected
- PQL Practical Quantitation Limit

This report shall not be reproduced except in full, without the written approval of the laboratory.
 The results reported relate only to the samples indicated.
 Soil/solid results are reported on a dry-weight basis unless otherwise noted.

RECEIVED

APR 24 2018

TOWN OF COUPEVILLE

Anatek Labs, Inc.

1282 Alturas Drive • Moscow, ID 83843 • (208) 883-2839 • Fax (208) 882-9246 • email moscow@anateklabs.com
504 E Sprague Ste. D • Spokane WA 99202 • (509) 838-3999 • Fax (509) 838-4433 • email spokane@anateklabs.com

Client: TOWN OF COUPEVILLE
Address: P.O. BOX 725
COUPEVILLE, WA 98239
Attn: JOSEPH GROGAN

Batch #: 180326034
Project Name: EPA 537

Analytical Results Report

Sample Number	180326034-001	Sampling Date	3/23/2018	Date/Time Received	3/26/2018 9:52 AM
Client Sample ID	WELL 1-08	Sampling Time	9:30 AM	Extraction Date	4/4/2018
Matrix	Drinking Water	Sample Location			
Comments					

Parameter	Result	Units	MDL	PQL	Analysis Date	Analyst	Method	Qualifier
Perfluorobutanesulfonic acid - PF ₄ S	ND	ug/L	0.025	0.09	4/10/2018	TGT	EPA 537	
Perfluoroheptanoic acid - PFHpA	0.0111	ug/L	0.005	0.01	4/10/2018	TGT	EPA 537	
Perfluorohexanesulfonic acid - PF ₆ S	0.0567	ug/L	0.005	0.03	4/10/2018	TGT	EPA 537	
Perfluorononanoic acid - PFNA	ND	ug/L	0.005	0.02	4/10/2018	TGT	EPA 537	
Perfluorooctanesulfonic acid - PF ₈ S	ND	ug/L	0.01	0.04	4/10/2018	TGT	EPA 537	
Perfluorooctanoic acid - PFOA	0.0640	ug/L	0.005	0.02	4/10/2018	TGT	EPA 537	