

Anatek Labs, Inc.

1282 Alturas Drive • Moscow, ID 83843 • (208) 883-2839 • Fax (208) 882-9246 • email moscow@anateklabs.com
504 E Sprague Ste. D • Spokane WA 99202 • (509) 838-3999 • Fax (509) 838-4433 • email spokane@anateklabs.com

Client: TOWN OF COUPEVILLE
Address: P.O. BOX 725
COUPEVILLE, WA 98239
Attn: JOSEPH GROGAN

Batch #: 190321058
Project Name: EPA 537

Analytical Results Report


Sample Number	190321058-001	Sampling Date	3/19/2019	Date/Time Received	3/21/2019 12:55 PM
Client Sample ID	FT CASEY	Sampling Time	9:15 AM	Extraction Date	3/26/2019
Matrix	Drinking Water	Sample Location			
Comments					

Parameter	Result	Units	MDL	PQL	Analysis Date	Analyst	Method	Qualifier
Perfluorobutanesulfonic acid - PFBS	ND	ug/L	0.025	0.09	3/26/2019	MER	EPA 537	
Perfluoroheptanoic acid - PFHpA	ND	ug/L	0.005	0.01	3/26/2019	MER	EPA 537	
Perfluorohexanesulfonic acid - PFHxS	0.0133	ug/L	0.005	0.03	3/26/2019	MER	EPA 537	J
Perfluorononanoic acid - PFNA	ND	ug/L	0.005	0.02	3/26/2019	MER	EPA 537	
Perfluorooctanesulfonic acid - PFOS	ND	ug/L	0.01	0.04	3/26/2019	MER	EPA 537	
Perfluorooctanoic acid - PFOA	0.0220	ug/L	0.005	0.02	3/26/2019	MER	EPA 537	

Sample Number	190321058-002	Sampling Date	3/19/2019	Date/Time Received	3/21/2019 12:55 PM
Client Sample ID	WELL 1-08	Sampling Time		Extraction Date	3/26/2019
Matrix	Drinking Water	Sample Location			
Comments					

Parameter	Result	Units	MDL	PQL	Analysis Date	Analyst	Method	Qualifier
Perfluorobutanesulfonic acid - PFBS	ND	ug/L	0.025	0.09	3/26/2019	MER	EPA 537	
Perfluoroheptanoic acid - PFHpA	0.0127	ug/L	0.005	0.01	3/26/2019	MER	EPA 537	
Perfluorohexanesulfonic acid - PFHxS	0.0645	ug/L	0.005	0.03	3/26/2019	MER	EPA 537	
Perfluorononanoic acid - PFNA	ND	ug/L	0.005	0.02	3/26/2019	MER	EPA 537	
Perfluorooctanesulfonic acid - PFOS	ND	ug/L	0.01	0.04	3/26/2019	MER	EPA 537	
Perfluorooctanoic acid - PFOA	0.0612	ug/L	0.005	0.02	3/26/2019	MER	EPA 537	

Authorized Signature



Kathleen A. Sattler, Lab Manager

J The reported value is between the laboratory method detection limit and the laboratory practical quantitation limit.
MCL EPA's Maximum Contaminant Level
ND Not Detected
PQL Practical Quantitation Limit

This report shall not be reproduced except in full, without the written approval of the laboratory.
The results reported relate only to the samples indicated.
Soil/solid results are reported on a dry-weight basis unless otherwise noted.